



# EMERGENCY VOICE COMMUNICATIONS

## OMNICARE REMOTES

### DISABLED TOILET ALARM

## VIGIL OmniCare

The Baldwin Boxall disabled toilet alarm is fully compliant to BS8300:2009. The British Standard requires all new disabled toilets to be fitted with an emergency toilet alarm. Our system provides a compliant, reliable and easy to use disabled persons toilet alarm. Products available in the range:

BVOCDTA • BVOCDTAS • BVOCDTAS2 • BVOCSSS • CRP • CRPS

#### IN THE KIT:

##### Controller:

Combined power supply and controller with reset/call acknowledge button, audible alarm and high visibility LED. (The 'call acknowledge' feature is set during installation.)

##### Pull switch:

Ceiling mounted pull cord (with two fully compliant 'G' pulls) and LED.

##### Reset point:

Reset button and LED to reset calls locally.

##### Light/sounder:

Over-door triangular lens with integral sounder to attract attention.

#### SYSTEM FEATURES:

- The disabled toilet alarm kit can be fitted as a component of the OmniCare EVC system or as a completely independent, stand-alone toilet alarm.
- Disabled toilet alarm units are connected to the VIGIL OmniCare system via a BVFREPEM repeater unit.
- Any number of disabled toilet alarms can be wired to each repeater (will show as one call point on master panel).
- Fully conforms to BS8300:2009 requirements.
- Call acknowledge feature (when enabled). Pressing the controller's 'reset' button acknowledges a call and changes the tone emitted by the over-door light/sounder. After 120 seconds the call reverts back to original alarm status.\*

\* This feature is not currently available from an Omnicare master panel.

- Integral power supply - requires mains power.
- Monitored battery backup.
- Powerful LEDs and sounder.
- 'Supply' and 'battery healthy' indicators.
- Two alarm modes (flashing or steady LEDs).
- Reset button enable/disable.
- Self test facility to ensure all sounders and LEDs are fully operational.
- Plug on terminals to ease installation.
- Supplied with disabled WC door sign.
- Up to three ring pulls can be fitted per 'station'.

#### PRODUCTS:

- BVOCDTA - disabled toilet alarm kit - white.
- BVOCDTAS - disabled toilet alarm kit - with stainless steel overdoor light and reset point.
- BVOCDTAS2 - disabled toilet alarm kit - all components in stainless steel.
- BVOCSSS - additional pull cord - white.
- BVOCSSS2 - additional pull cord - stainless steel.
- CRP - slave reset point - white.
- CRPS - slave reset point - stainless steel.

## DISABLED TOILET ALARM KIT SPECIFICATION:

	Controller	Over-door light / sounder	Reset point	Ring pull (white)	Ring pull (stainless steel)
Power supply	220-240V AC				
Output	12V DC				
Fuse	Internal thermal				
Alarm type	90dB @ 30cm				
Battery backup	Alkaline - type A23 12V				
Dimensions mm WxHxD	85x145x13	85x85x13	85x85x13	30x80 (diameter)	85x85x18
Cable requirements	4 or 6 core security alarm cable 7/0.2 or similar				
Back box requirements (not supplied)	35mm deep double gang, flush back box or 'round cornered' surface box	25mm deep single gang flush back box or 'round cornered' plastic surface box		Supplied with its own surface mount enclosure	25mm deep single gang flush back box or 'round cornered' surface box

### ALTERNATIVE PRODUCT OPTION - CallCare:

For systems requiring multiple call points including warden/nurse calling, panic alarms, toilet/bathroom alarms, etc, please refer to our leaflet on CallCare.

#### Please note:

The disabled toilet alarm provides a visual and audible alert at the main console, speech communication is not possible.

The toilet alarm kits featured on this sheet are NOT compatible with CallCare products. (Please contact our sales department who will be happy to provide assistance with your specification.)

# BALDWIN BOX▲LL

TEL: +44 (0) 1892 664422  
FAX: +44 (0) 1892 663146

EMAIL: MAIL@BALDWINBOXALL.CO.UK  
WEB: WWW.BALDWINBOXALL.CO.UK

BALDWIN BOXALL COMMUNICATIONS LTD  
WEALDEN INDUSTRIAL ESTATE,  
FARNINGHAM ROAD, CROWBOROUGH,  
EAST SUSSEX, TN6 2JR, UNITED KINGDOM.



WE RESERVE THE RIGHT TO CHANGE THE PRODUCT SPECIFICATION WITHOUT PRIOR NOTICE OR LIABILITY. DOC NO. 1.0012.011

## BALDWIN BOX▲LL

## LEADING THE WAY TO SAFETY